



**Department
of Health**

ANDREW M. CUOMO
Governor

HOWARD A. ZUCKER, M.D., J.D.
Commissioner

SALLY DRESLIN, M.S., R.N.
Executive Deputy Commissioner

November 2, 2016
NOTICE OF VIOLATION
New York State Sanitary Code, 10 NYCRR Part 5

Clifton Supervisor & Town Board
Town of Clifton
PO Box 684
Cranberry Lake, NY 12927

Re: Public Water System
Newton Falls Water District
PWS ID: NY4404403

Dear Supervisor and Town Board Members:

This violation is a result of Newton Falls Water District's failure to meet Section 5-1.63 of the New York State Sanitary Code for Disinfection By-Product Precursor Removal (% TOC Removal) for the time period July 1 through September 30, 2016. The % TOC removal is based on a running annual average that is calculated quarterly. You are required to make public and consumer notification regarding this violation within one year.

Public Notification can be satisfied for this violation by reporting this in the 2016 Annual Water Quality Report.

Failure to comply with notification requirements may result in enforcement action and fines.

Sincerely,

Joseph L. Brant, P.E.
Public Health Engineer 2
Canton District Office

New York State Department of Health
58 Gouverneur St., Canton, NY 13617
P: 315-386-1040 F: 315-386-1043
joseph.brant@health.ny.gov
www.health.ny.gov

cc: Mark Hall, DANC
File